



**ELEVATION**

**NOTES:**

1. S1 = NAIL SPACING AT WALL SHEATHING EDGES  
S2 = NAIL SPACING AT WALL INTERMEDIATE MEMBERS
2. SEE SHEAR TABLE FOR NAIL SPACING.
3. PLYWOOD SHEATHING SHALL BE 1/2" THICK MIN. STRUCTURAL NO. 1 PLYWOOD.

**TYP. WALL SHEATHING NAILING DETAIL**

| SEISMIC ZONE | WIND EXPOSURE | DRAWING NUMBER |
|--------------|---------------|----------------|
|              | C             | 1B             |